



Water Hardness per System (May 2026)

Water System Number	Water System Name	General Area	Parts per Million (PPM)		Grains per Gallon (GPG)		Iron (PPM)
			Range	Average	Range	Average	Average
10-092	Picture Rocks	Continental Reserve/Picture Rocks/Cortaro & Silverbell	210 to 220 (2 Wells)	215	12	12	<0.050
10-136	Palo Verde	Twin Peaks & Clayton	220 (1 Well)	220	12	12	<0.050
10-138	Airline/Lambert	Avra Valley Rd/Airline Rd/Lambert Ln/Saguaro Bloom/Silverbell Rd & Linda Vista	210 to 220 (2 Wells)	215	12	12	0.20
10-150	Marana Municipal	Gladden Farms/Rancho Marana/Honea Heights/Yoem Pueblo/Marana Main Street/Tangerine	110 to 200 (3 Wells)	145	6 to 12	9	<0.010
10-150	Marana Municipal	San Lucas/Warfield Circle/Amole Circle	110 (1 Well)	110	6	6	<0.010
10-329	Hartman Vistas	Hartman Vistas/Hartman 10/Oasis Hills/Oshrin Park/Cortaro Crossings/Shady Grove/Red Rock Village/Willow Ridge/Twin Peaks & I-10	56 to 100 (2 wells)	76	3 to 6	5	<0.05
10-406	Airport	Marana Regional Airport	230 to 260 (2 wells)	245	13 to 15	14	1.50